

施設	点検箇所	点検項目	点検頻度	日付																														特記事項						
				1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30							
浸出水処理施設	砂ろ過設備	砂ろ過器	水位の確認	稼働時																																				
			透視度の確認																																					
			ポンプの稼働状況																																					
			差圧計の確認																																					
			内部砂流動の確認																																					
			エアリフト管の状況																																					
			エア量の確認																																					
			エア圧力の確認																																					
		コンプレッサー	コンプレッサーの稼働状況	稼働時																																				
			空気槽圧力の確認																																					
		除湿装置	除湿装置の稼働状況	稼働時																																				
			除湿装置内圧力の確認																																					
		消毒・放流槽	処理水ピット	稼働時																																				
			塩素混和槽	稼働時																																				
			放流槽	稼働時																																				
		薬品注入設備	薬注ポンプ	1回/日	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○		
			薬品タンク	1回/日	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○		
			薬注配管等	稼働時	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	
				稼働時	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	
		汚泥処理設備	汚泥ピット	稼働時																																				
			汚泥濃縮槽	稼働時																																				
			汚泥貯留槽	稼働時																																				
			汚泥脱水機	稼働時				○							○																									
			汚泥ホッパ	稼働時																																				
			脱水助剤自動溶解装置	稼働時																																				
			給排水設備	1回/日	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	
			配管設備	1回/日	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	
		各機器	ポンプの吐出圧、振動、騒音	1回/日	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○		
			タンクの漏水	1回/日	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○		
			計器の作動、指示	1回/日	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	
	水中ポンプの点検		1回/日	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○		
	電気設備	スケール除去、オイル交換、グリースアップ	1回/日	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○			
		各機器の異常	1回/年																																					
	その他	漏電、絶縁測定、その他ケーブル等劣化計測、継電器等リレー試験、機器	1回/年																																					
		暖房ヒーターの異常(冬期使用時)	1回/日	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○			
		換気扇の異常	1回/日	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○		
		照明器具の異常	1回/日	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	
	水量	灯油タンク、オイルサーバー、配管の異常	1回/日	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○			
		消防設備の異常	1回/日	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○		
		放流水固形塩素剤の充填状況の確認	1回/日	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○		
		浸出水量	1回/日	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○		
		原水流量	1回/日	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○		
	水量	放水量	稼働時																																					
		返水量	稼働時																																					
		汚泥供給量	稼働時																																					
		汚泥搬出量	稼働時																																					

点検の結果の表示: ○:異常なし ×:異常あり △:修理補修