




第 4 章

亀吉雨水ポンプ場運転状況



ユキウサギ

エゾタヌキ

〔 下水処理センター構内にある、滝のトイレ内
ギャラリーに展示してある動物たち 〕

1. 運転状況

(その1)

項目 月	沈砂池	総合	電力量供給別内訳			
	除去物 月量 t	総使用 電力量 kWh	取引用電力量			自家発 非常用 kWh
			月量 kWh	力率 %	最大電力 kW	
4	0.0	22,496	22,496	100	137	0
5	0.0	16,921	16,921	100	78	0
6	0.0	16,406	16,406	100	37	0
7	0.0	17,705	17,705	100	136	0
8	0.0	18,151	18,120	100	177	31
9	0.0	16,678	16,678	100	92	0
10	0.0	17,778	17,778	100	125	0
11	0.0	23,602	23,602	100	163	0
12	0.0	31,673	31,673	100	51	0
1	0.0	34,373	34,373	100	30	0
2	0.9	29,777	29,777	100	69	0
3	0.0	28,558	28,558	100	114	0
合計	0.9	274,118	274,087	—	—	31
日平均	0.00	752	752	100	—	—
日最大	—	1,108	1,108	—	177	—
日最小	—	545	545	—	—	—

(その2)

項目 月	フィーダ別需要内訳						
	電動 ポンプ kWh	本館動力 kWh	沈砂池棟 kWh	雨水 ポンプ棟 kWh	照明設備 kWh	本館井戸 kWh	その他 kWh
4	29	1,341	1,262	2,370	6,038	121	11,335
5	33	273	1,295	1,442	5,617	112	8,149
6	23	57	1,198	894	5,065	88	9,081
7	25	48	1,259	578	5,157	218	10,420
8	43	48	1,482	492	5,204	203	10,679
9	0	45	1,434	649	4,991	164	9,395
10	40	617	1,248	1,237	5,757	102	8,777
11	21	1,594	1,197	2,136	6,270	77	12,307
12	21	2,490	1,294	3,067	7,713	117	16,971
1	24	2,680	1,349	3,564	8,278	82	18,396
2	19	2,339	1,200	3,088	7,212	79	15,840
3	23	2,141	1,449	3,004	7,498	152	14,291
合計	301	13,673	15,667	22,521	74,800	1,515	145,641
日平均	1	37	43	62	205	4	399
日最大	33	88	262	122	336	89	634
日最小	0	0	34	10	148	0	191